



Notes:

1. Discharge positions viewed from the drive end.
2. Consult factory for other discharge positions.

PUMP DIMENSIONS

Model	Frame	Connection		A	B	C	D	DD	E	F	H	L	M	MA
		Disch.	Suct.											
4NMPP	F5	4	4	7.5	7.36	23.69	5.5	11	2.62	4.5	0.56	13.75	25.78	11.28
	F16	4	4	12	12.88	30.25	9.75	11	5.12	10.38	0.81	12.38	25.78	11.28

PUMP DIMENSIONS (continued)

MB	N	O	P	Q	R	S	U	V	W	X	Y	Z	KEYWAY
11.5	1.25	21.62	1.38	1.75	16.75	2.5	1.25	3	8	11	1.56	6.25	.25 X .12
11.5	1.25	21.62	0.88	1.75	16.75	2.5	2	4.5	8	11	1.56	6.25	.50 X .25

Notes:

1. Dimension "Q" is maximum adjustment for field weld.
2. "V" dimension is maximum useable shaft.
3. Frame mounting foot thickness is .62".
4. Dimension "DD", "M", "MA", and "R" shown are for top vertical position only.
5. Flange connection dimension can vary $\pm .12$ inch.
6. Do not use for construction unless certified.

Cornell Pump Company
 P.O. Box 6334
 Portland, Oregon 97228-6334
 Web: www.cornellpump.com
 Phone (503) 653-0330 • Fax (503) 653-0338